

Alta Irrigation District

General Construction Notes

1. All work shall conform with the standards and requirements shown on the project plans and specifications.
2. All material shall be new and no salvaged material or previously used material may be used unless approved by the District's engineer.
3. All disturbed soil and pipe bedding shall be compacted to a minimum of 90% maximum density. Contractor shall be responsible for compaction tests and all test shall be provided to the District's engineer.
4. All bends and/or elbows shown are precast unless specified differently and shall conform to ASTM standards.
5. All excess material and/or debris shall be removed upon completion of the installation.
6. Construction shall not interfere with the flow or distribution of water as required by the District. All improvements shall be construction in a manner to allow flood flows to pass at all times.
7. The Contractor shall be responsible for any water that may flow in the irrigation facility or area of construction during the time of installation.
8. Alta Irrigation District, (559) 591-0800, shall be notified to determine a time period that work may be performed.
9. Alta Irrigation District, (559) 591-0800, shall be notified 48 hours prior to construction. No work shall begin without written permission of Alta Irrigation District's General Manager.
10. All irrigation pipe installed for use by the District shall be inspection and approved by the District's field inspector before backfilling may occur.
11. Pipe shall be bedded in sand from 3 inches below the pipe to 1 foot above the top of pipe.
12. Locator taped marked, "Caution Irrigation Pipeline Buried Below," shall be laid on top of the sand bedding.
13. All encroachments (including tree selection) within the Alta Irrigation District 's easement shall be approved by the District.
14. Pipeline and appurtenances are to be installed according to the details and elevations shown on the plans approved by the District.
15. Alta Irrigation District pipeline shall be a minimum of RGRCP Class 3 spun pipeline. The Class shall be upgraded if required by the site conditions.
16. An encroachment permit will be required for all utility crossings within the Alta Irrigation District right-of-way.