



NOTES:

1. MORTAR LINING AND COATING TO BE REINFORCED WITH WIRE FABRIC.
2. FOR IRRIGATION TURNOUT OR CONNECTION PROVIDE SAME OUTLET AND ROTATE HORIZONTAL.
3. SEE PLATE 5 FOR EXPANDED METAL COVER DETAIL.
4. MANHOLE/AIR VENT SHALL BE PROVIDED AS A COMPLETE UNIT FROM THE PIPELINE MANUFACTURER. FIELD FITTING OF OUTLET IS NOT PERMITTED.

MANHOLE/AIR VENT

NTS